

CERTIFICATE of Conformity



Certificate No.: MK 69249972 0001

Test Report No.: 28220810 005

Certificate Holder: DALAP GmbH
Töpfergasse 72
09526 Olbernhau
Germany

Manufacturer: ---

Product: FANS
Duct fans

Identification: Type designation: Dalap AP xxx QUIET
Trade Mark: Dalap
Rated voltage: 220-240V; 50Hz
Degree of protection: IPX4
Protection class: II
Tamb: 1-40°C; tropical climate

See detailed information in Annex.

Tested according to: EN 60335-2-80:2003+A1+A2
EN 60335-1:2012+A11
EN 62233:2008

This certificate refers to the above mentioned product. This is to certify that the test sample is in conformity with the requirements stated above. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Date of Issue:

Budapest, 2015.06.18



Identical fan type Dalap AP ... QUIET series	Rated power (W)
AP 100 QUIET	24/26
AP 125 QUIET	25/30
AP 150 QUIET	45/52
AP 200 QUIET	78/110
AP 250 QUIET	127/178
AP 315 QUIET	213/313

The meaning of characters:

Dalap: trade mark;

AP ... QUIET: design;

xxx: diameter of the duct [mm]. It can be: 100,125,150,200,250,315;

Certification Body

Date of issue:

Budapest, 2015.06.18.



Zoltan Rostas

TÜV Rheinland InterCert Kft. – Product Certification Body — H-1132 Budapest, Váci út 48/A-B — www.tuv.hu